



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Fire Lane Establishment Order Martha B. Gudelsky Child Development Center	Executive Order No. 025-21	Subject Suffix
Originating Department Montgomery County Department of Permitting Services	Department Number MCDPS 2-21	Effective Date 3/4/2021

Fire Lane Establishment Order

Pursuant to Section 22 - 33, Montgomery County Code, 1971, as amended, you are hereby notified that a Fire Lane has been established as described in this order. You are hereby ordered to post fire lane signs and paint curbs/pavement (painting optional) as identified below. When signs and paint work (painting optional) have been completed, this order will authorize the enforcement of this Fire Lane by appropriate police and fire officials. Compliance with this order must be achieved within 30 days of receipt.

LOCATION: 8901 Colesville Rd.

All areas where indicated by signs and paint.

☒ SIGNS - - (See attached diagram for location of sign placement)



\$250 FINE

FIRE LANE

Signs must be posted so that it is not possible to park a vehicle without being in sight of a sign. Signs may be no further apart than 100 feet

(Red letters on white background)

☐ PAINT - - (See attached diagram if painting).

Paint must be traffic yellow with lines of sufficient width to be readily identifiable/readable by motor vehicle operators.

Richard E. Merck Digitally signed by Richard E. Merck
Date: 2021.03.08 09:34:26 -05'00'

Fire Marshal, Montgomery County Department of Permitting Services

FIRE LANE ESTABLISHMENT FORM


BUILDING OR SUBDIVISION NAME: Martha B. Gudelsky Child Development CenterFIRE LANE LOCATION/ADDRESS: Private Drive between Colesville Road and
Ellsworth Drive at 8901 Colesville Road

See attached drawing for designated fire lanes:

I have received the drawing and instructions for installing the designated fire lanes on property not owned by state or local government.

NAME AND TITLE OF PROPERTY REPRESENTATIVENAME: Joseph D. Horton TITLE: Vice President, Construction & DevelopmentSIGNATURE: PHONE: (301) 622-0100 DATE: February 22, 2021

ADDRESS (where processed order will be mailed):

11900 Tech Road, Silver Spring, MD 20904-----
The designated fire lanes are the minimum necessary for fire/rescue access and are in accordance with Section 22-33 of the Fire Safety Code.NAME: Marie LaBaw SIGNATURE: STA.#: DPS I.D.#: LS1189 DATE: 2/26/2021

Comments: _____

Fire Lane Installed Per Order

NAME: _____ DATE: _____